

NOTICE: SMOKING IS PROHIBITED IN EXHIBIT AREAS DURING MOVE-IN AND MOVE-OUT DUE TO THE ACCUMULATION OF COMBUSTIBLE MATERIALS.

- 1. ALL MATERIALS USED IN CONSTRUCTION AND DECORATION OF AN EXHIBIT MUST BE FLAME RETARDANT.** Fabrics must be certified as flame retardant or a sample must be available for testing. Materials which cannot be treated to meet the requirements may not be used.
- 2. ALL EXITS AND EXIT AISLES MUST BE KEPT CLEAR AND UNOBSTRUCTED.** No furniture, signs, easels, chairs or displays may protrude into aisles.
- 3. DESIGNATED "NO FREIGHT" AISLES MUST BE MAINTAINED CLEAR OF CRATES AND EXHIBIT MATERIALS DURING MOVE-IN AND MOVE-OUT.** These aisles are required for emergency access throughout the hall and to expedite freight and empty crate moving.
- 4. ALL FIRE HOSE RACKS, FIRE EXTINGUISHERS AND EMERGENCY EXITS MUST BE VISIBLE AND ACCESSIBLE AT ALL TIMES.** This includes fire protection equipment located within exhibits. Exits and exit signs must not be covered by drapes nor obscured from view by exhibit components.
- 5. EXHIBITORS WHO INTEND TO DISPLAY A VEHICLE WITHIN THE CONFINES OF THEIR EXHIBIT BOOTH MUST OBTAIN A VEHICLE DISPLAY PERMIT FROM THE CLARK COUNTY FIRE MARSHAL.** To obtain an application, please download the "Display of Motor Vehicles in Assembly Occupancies" form at <http://fire.co.clark.nv.us/Permits.aspx>. Vehicles on display must have fuel filler caps locked or sealed to prevent escape of vapors and to avoid tampering. Batteries must be disconnected. Auxiliary batteries not connected to engine starting system may be left connected. External chargers are recommended for demonstration purposes.

EXCEPTION: Permits are not required at the Las Vegas Convention Center. However, vehicles that use compressed gas are prohibited. Vehicles containing multiple batteries will need prior approval from the LVCVA Safety Office.

- 6. COMBUSTIBLE MATERIALS MUST NOT BE STORED BENEATH DISPLAY VEHICLES.** Space beneath vehicles must be clear and visible except for permitted electrical supplies.
- 7. VEHICLES IN BUILDING FOR UNLOADING MUST NOT BE LEFT WITH ENGINE IDLING.** Exhaust gases present extreme hazards to workers on catwalks. If engine cannot be shut down, vehicle must be removed from the building as quickly as possible.
- 8. COMPRESSED GAS CYLINDERS, INCLUDING LPG, ARE PROHIBITED UNLESS APPROVED BY OFFICE OF FIRE PROTECTION AND SAFETY.** Flammable gases, i.e.: butane, propane, natural gas, et al; are subject to prior approval. Non-flammable compressed gas cylinders must be secured in an upright position with gauges and regulator protected against physical damage.

EXCEPTION: The Las Vegas Convention Center's Propane Regulations are available online at: <http://lvcva.com/meetings/meeting-venues/convention-centers/info/lvcc-fire-safety.jsp>.

- 9. ALL 110 VOLT EXTENSION CORDS SHALL BE THREE-WIRE (GROUNDED), #14 OR LARGER AWG, COPPER WIRE. ALL CONNECTIONS MUST BE SUPPORTED AND SECURE.** Two wire, "Zip Cords" are not permitted other than factory installed appliance connectors; these may not exceed six (6) feet in length and must be UL approved.
- 10. CUBE TAP ADAPTERS ARE PROHIBITED (UNIFORM FIRE CODE 85.107). MULTI-PLUG CONNECTORS MUST BE UL APPROVED WITH BUILT-IN OVERLOAD PROTECTION.** Connectors must not be used to exceed their listed ampere rating.
- 11. ELECTRICAL WORK UNDER CARPETS OR FLOORING MUST BE INSTALLED BY THE OFFICIAL ELECTRICAL SERVICE PROVIDER.** All cords must be flat, three conductor, #14 AWG or larger.
- 12. ALL TEMPORARY WIRING MUST BE ACCESSIBLE AND FREE FROM DEBRIS AND STORAGE MATERIALS.** Hard backed booths must have power supplies dropped within the booth.
- 13. NO STORAGE OF ANY KIND IS ALLOWED BEHIND BOOTHS OR NEAR ELECTRICAL SERVICE.** Materials for hand-outs must be limited to one day supply and stored neatly within the booth. Violators will be notified and if not removed by show opening, Official Service Contractor will remove and store at **EXHIBITOR'S EXPENSE**.
- 14. CLARK COUNTY WILL CURRENTLY ALLOW COVERED EXHIBITS UP TO 1000 SQUARE FEET TO BE UNSPRINKLED.** All covered exhibits greater than 1000 square feet must be provided with sprinklers throughout.
- 15. MULTI-STORY EXHIBIT BOOTHS MUST BE APPROVED BY THE CLARK COUNTY FIRE MARSHAL.** Guidelines and an Application for Permit are available online at <http://fire.co.clark.nv.us/Permits.aspx>.

EXCEPTION: The Las Vegas Convention Center's regulations for Covered and/or Double Deck Exhibits are available online at: <http://lvcva.com/meetings/meeting-venues/convention-centers/info/lvcc-fire-safety.jsp>.

- 16. TEMPORARY MEMBRANE STRUCTURES, TENTS AND CANOPIES IN EXCESS OF 200 SQUARE FEET WITHIN THE EXHIBIT FACILITY MUST BE APPROVED BY THE CLARK COUNTY FIRE MARSHAL.** Guidelines and an Application for Permit are available online at <http://fire.co.clark.nv.us/Permits.aspx>.
- 17. ALL EMPTY CARTONS OR CRATES MUST BE LABELED AND REMOVED FOR STORAGE OR THEY WILL BE REMOVED AS TRASH.** Crates are not to be used as exhibit supports.
- 18. FLAMMABLE OR COMBUSTIBLE LIQUIDS ARE PROHIBITED INSIDE OF BUILDINGS EXCEPT AS APPROVED BY THE OFFICE OF FIRE PROTECTION AND SAFETY.** Flammable thinners, solvents and paints, including aerosol cans are strictly prohibited within the building.